



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
REGION 10  
WASHINGTON OPERATIONS OFFICE  
300 Desmond Drive SE, Suite 102  
Lacey, Washington 98503

October 19, 2016

FILE COPY

Leslie Rima  
Spoko Fuels – West Plains  
P.O. Box 550C Hwy 25 S  
Davenport, WA 99122

Re: Underground Storage Tank (UST) Program Field Notice of Non-Compliance For Tribally Owned Facility No. 084 from the June 14, 2016, UST facility inspection of Spoko Fuels – West Plains (EPA ID No. 4190012)

Dear Ms. Rima:

The information that was received on October 4, 2016, satisfies the terms specified in Field Notice of Non-Compliance (FNNC) No. 084, which was issued on June 14, 2016, for your facility. Therefore, EPA has granted final approval of this FNNC. Thank you for taking the necessary steps to bring your facility into compliance with the federal UST regulations.

To remain in compliance and to avoid being issued additional field notices of non-compliance or possible enforcement actions with monetary penalties, please remember to do the following:

- Continue to have your Veeder-Root tank gauge conduct CSLD leak tests **monthly** and save the test reports.
- Conduct line tightness testing **annually** **OR** have the electronic line leak detectors (PLLDs) conduct **monthly** leak tests. Print and save the reports with the tank CSLD reports.
- Continue to have the automatic line leak detectors tested **annually**.

As a reminder, please continue to maintain your UST insurance, perform monthly tank release detection testing, and keep your spill buckets clean and dry. You do not need to send in subsequent test results to us, but rather, they should be kept with your UST records and be available for review upon request by EPA.

If you have any questions in reference to this inspection, please call me at (360) 753-8072.

Sincerely,

  
Jim Greeves  
UST Inspector

Cc: Judy Flett, Spokane Tribe of Indians